

certificate
no. **BAU 24040**
dated 2024-02-21

Translation In any case, the German original shall prevail.

EuroTest Certificate

Name and address of the holder of the certificate: (customer) SBH Tiefbautechnik GmbH
Ferdinand-Porsche-Str. 8
52525 Heinsberg
GERMANY

Product designation: **Margin-supported trench shoring system, made of steel**

Type: Transformation profile for shoring panels of the 600er series

Testing based on: EN 13331-2:2002
EN 13331-1:2002
DIN 4124:2012

Test report: 2018 0176 009, 2023 0135 08

Further details: Box height: 3.71 m with strut clearance height 2.36 m
Box height: 3.92 m with strut clearance height 2.57 m
Permissible bending moment beneath the pinning: 211 kNm
Permissible bending moment in the area of the pinning: 249 kNm

Intended use:
In accordance with the manufacturer's instructions for use and operation.

Maximum permissible earth pressure:
See manufacturer's instructions for use and operation

Subsequent certificate to number BAU 19036.


The manufacturer is also Certificate holder.

The type tested complies with the test basis specified above.

The holder of the certificate is entitled to affix the ET-mark shown overleaf to the products complying with the type tested.

The present certificate including the right to affix the ET-mark is valid until: **2029-02-20**

Further provisions concerning the validity, the extension of the validity and other conditions are laid down in the Rules of Procedure for Testing and Certification.


Dipl.-Ing. (EH) Franz Welsch
Deputy Head of Certification Body

